

TSP Name / TSP: EASTERN GAS TRANSMISSION AND STORAGE INC (116025180)

Critical: N

Notice Eff Date: 05/27/2021

Posting Date: 05/27/2021

Notice Eff Time: 10:04 AM

Posting Time: 10:04 AM

Notice Stat Desc: Supersede

Notice ID: 234532

Notice Type Desc: Planned Service Outage

Prior Notice: 234293

Reqrd Rsp Desc: No response required

Response Date:

Response Time:

Subject: 2021 Annual Facility Outage Update as of 05/27/2021

Notice Text:

AFFECTED CUSTOMERS WILL BE NOTIFIED OF RESPECTIVE OUTAGES

Revised	Facility	Down Time (Days)	Out of Service	Back in Service	Reason for Outage	Service Impact
	Leidy	473	02/14/2020	06/01/2021	#7 Overhaul Prep	
	Cornwell	148	01/04/2021	06/01/2021	#19 Inspection 8K	
	Groveport	275	03/01/2021	11/30/2021	#2 Foundation Replacement	
	Woodhull	64	03/29/2021	06/01/2021	#4 Cooler Replacement	
	Greenlick	63	04/19/2021	06/21/2021	Unit #1 Gas Cooler, JW / AW Cooler Maintenance	
	Gilmore	32	04/26/2021	05/28/2021	#5 8k Inspection	
	TL-344	25	04/28/2021	05/23/2021	Outage Lightburn to Tompson Jct.	
	Harrison	31	05/03/2021	06/03/2021	Unit #4 Unavailable	
	Ardell I	105	05/10/2021	08/23/2021	Install F/S & Underground Check Valve	
	FKLC	20	05/12/2021	06/01/2021	Flow Test	
	Greenlick	22	05/13/2021	06/04/2021	B&C Train Work	
	Beaver Sta.	14	05/18/2021	06/01/2021	Engine Mapping	
	Chambersburg	9	05/23/2021	06/01/2021	#3 Emissions Test	
	TL-379	8	05/24/2021	06/01/2021	Outage Woodhull to Addison	
	LL Tonkin	8	05/24/2021	06/01/2021	#1 Vibration	
	JP-120	2	05/24/2021	05/26/2021	Outage for Line Maintenance.	
	Brookmans	2	05/26/2021	05/28/2021	Maintenance on # 3 and # 4 one at a time	
	Leidy Sta.	2	05/26/2021	05/28/2021	Welding on #7; Limited Injection	Possible Sec & IT
	TL-414	6	05/29/2021	06/04/2021	Outage Lightburn to TL-414 Ball launcher	
	LN-679	1	06/01/2021	06/01/2021	Cleaning Pig Run from LN-688 to Woodhull	
	Quinlan	1	06/01/2021	06/01/2021	#1-2 Emissions Test	
	Leidy	29	06/01/2021	06/30/2021	Boiler Maintenance	
	TL-379	5	06/01/2021	06/06/2021	Outage Addison to Lindley	
	JB Tonkin	1	06/01/2021	06/01/2021	Rebuild CC Valve	

	Loup Creek	1	06/01/2021	06/01/2021	#4 Emissions Test	
	TL-255	87	06/01/2021	08/27/2021	Outage Horseneck to McIntire Jct.	Possible Firm, Sec & IT
	Punxsutawney	5	06/01/2021	06/06/2021	Glycol Remediation	
	LN-679	1	06/03/2021	06/03/2021	Mag Pig Run from LN-688 to Woodhull	
	LN-31	8	06/04/2021	06/12/2021	Outage Big Flats to Sullivanville	
	LP-101	1	06/07/2021	06/07/2021	MFL Pig Run from Crossover 1 to Leidy	
	LN-280	1	06/07/2021	06/08/2021	Cleaning Pig Run from Valley to Ardell	Possible Firm, Sec & IT
	TL-257	4	06/07/2021	06/11/2021	Outage Foley Jct. to Sweeney	
	Mullett	1	06/07/2021	06/07/2021	#2 & 3 Emissions Test	
	LN-31	16	06/07/2021	06/23/2021	Outage Freeville to Cortland High	
	LN-15	5	06/07/2021	06/12/2021	Outage Wolcott to Sanford	Possible Firm, Sec & IT
	Sabinsville	6	06/07/2021	06/13/2021	Glycol Remediation	
	TL-390	1	06/08/2021	06/08/2021	MFL Pig Run from Beginning of 16" line to Greenlick	
	Tioga	1	06/08/2021	06/08/2021	#1-2 Emissions Test	
	LN-554	1	06/08/2021	06/08/2021	Cleaning Pig Run from Genessee Falls to Caledonia	
*	Mockingbird	1	06/08/2021	06/08/2021	Capped ESD	
	LN-554	1	06/09/2021	06/09/2021	Mag Pig Run from Genessee Falls to Caledonia	
	JP-120	3	06/09/2021	06/12/2021	Outage South Oakford to Frey's Gate	
	LN-280	1	06/09/2021	06/10/2021	12"Mag Pig Run from Valley to Ardell	Possible Firm, Sec & IT
	South Oakford	1	06/09/2021	06/09/2021	Capped ESD	
	LN-679	1	06/10/2021	06/10/2021	MFL Pig Run from LN-688 to Woodhull	
	LP-2	1	06/10/2021	06/10/2021	Mag Pig Run from Beaver Dam to Leidy	
	TL-474	9	06/12/2021	06/21/2021	Outage Valley Gate 29-A to Southbend	
	Little Greenlick	1	06/14/2021	06/14/2021	#1-3 Emissions Test	
	LN-280	1	06/14/2021	06/15/2021	Caliper Pig Run from Valley to Ardell	Possible Firm, Sec & IT
	TL-260	4	06/14/2021	06/18/2021	Outage Compton Jct. to Charles Point Jct.	
*	Morrisville	1	06/14/2021	06/14/2021	Controller Rebuild	
	Woodhull	7	06/14/2021	06/21/2021	Unit #1 Pocket Automation	
	Wyoming	4	06/14/2021	06/18/2021	Outage Wyoming M&R	
	LN-30	18	06/15/2021	07/03/2021	Outage Morrisville to DeansBoro	
	TL-263	9	06/15/2021	06/24/2021	Outage Loup Creek to Pond Fork	Possible Firm, Sec & IT
	LN-280	1	06/16/2021	06/17/2021	MFL Pig Run from Valley to Ardell	Possible Firm, Sec & IT
	LP-2	1	06/16/2021	06/16/2021	Caliper Pig Run from Beaver Dam to Leidy	
	LN-1	6	06/16/2021	06/22/2021	Outage Big Flats to Sullivanville	
	LP-2	1	06/17/2021	06/17/2021	MFL Pig Run from Beaver Dam to Leidy	
	LN-20	4	06/21/2021	06/25/2021	Outage Big Springs to Clermont	Possible Sec & IT
	LN-280	7	06/21/2021	06/28/2021	Outage Valley Gate 29 to Smicksburg	
	TL-342	8	06/21/2021	06/29/2021	Outage Pumpkin Farm to JB Tonkin	Possible Firm, Sec & IT
	JB Tonkin	3	06/21/2021	06/24/2021	Glycol Remediation	

	Leidy	9	06/21/2021	06/30/2021	#1-12 Emissions Test	
	LN-30	21	06/21/2021	07/12/2021	Outage Amsterdam to Kings Road	Possible Sec & IT
	LN-30	21	06/21/2021	07/12/2021	Outage Kings Road to Wolf Road	Possible Sec & IT
	Albany/Wolf Rd	21	06/21/2021	07/12/2021	Wolf Rd M&R, Replace 4 Valves	
	Woodhull	7	06/21/2021	06/28/2021	Units #1, #5, #6 Pocket Automation & Mufflers	
	TL-345	6	06/21/2021	06/27/2021	Stoppie TL-345 Reg	
	LN-554	1	06/22/2021	06/22/2021	MFL Pig Run from Genessee Falls to Caledonia	
	LN-554	10	06/23/2021	07/03/2021	Outage Stateline To Robinson	
	JP-45	3	06/23/2021	06/26/2021	Outage Oakford to Kling	
	LN-31	9	06/24/2021	07/03/2021	Outage Boom to Lindley	
	Woodhull	21	06/28/2021	07/19/2021	Units #5, #6 Pocket Automation & Mufflers	
	LN-20	4	06/28/2021	07/02/2021	Outage McDowell to Hemphill	Possible Firm, Sec & IT
	LN-378	7	06/28/2021	07/05/2021	Outage Valley Gate 29-A to Veahman Hill	
	UP-1	8	07/01/2021	07/09/2021	Cleaning Pig Run from UP-13 to UP-7	
	Sabinsville	1	07/05/2021	07/05/2021	#8 & 9 Emissions Test	
	LN-50	7	07/05/2021	07/12/2021	Outage Valley Gate 29 to Smicksburg	
	LN-1	16	07/06/2021	07/22/2021	Outage Boom to East Corning	
	Craigs	2	07/07/2021	07/09/2021	Outage Craigs M&R	
	UP-1	1	07/07/2021	07/07/2021	10" Mag & Caliper Pig Runs from UP-17 to UP-16	
	UP-1	1	07/08/2021	07/08/2021	10"MFL Pig Run from UP-17 to UP-16	
*	Bridgeport	1	07/09/2021	07/09/2021	Capped ESD Test & MCC work	
	State Line	1	07/12/2021	07/12/2021	#1-4 Emissions Test	
	Angelica	4	07/12/2021	07/16/2021	Outage Angelica M&R	
	UP-1	1	07/12/2021	07/12/2021	12" Mag & Caliper Pig Runs from UP-16 to UP-13	
	TL-587	7	07/12/2021	07/19/2021	Outage Rural Valley to Valley Gate 29-A	
	Leesburg	1	07/13/2021	07/13/2021	Engine # 3 Annual Maintenance (Solar)	
	UP-1	1	07/13/2021	07/13/2021	12" MFL Pig Run from UP-16 to UP-13	
*	Morrison Sta.	1	07/14/2021	07/14/2021	Capped ESD Test	
	LN-532	11	07/15/2021	07/26/2021	Outage Schenectady M&R to Lainheart	Possible Sec & IT
	TL-470	11	07/15/2021	07/26/2021	Outage Schenectady GA-132B to GA-132	Possible Sec & IT
	Woodhull	28	07/19/2021	08/16/2021	Units #3, #4 Pocket Automation, Mufflers	
	TL-342	5	07/19/2021	07/24/2021	Outage Mockingbird to Lambert	
	Beaver	1	07/19/2021	07/19/2021	#1-4 Emissions Test	
	LN-26	4	07/19/2021	07/23/2021	Outage Mcilwain to Southbend	
	LN-550	9	07/20/2021	07/29/2021	Outage Cheningo to Deruyter	Possible Firm, Sec & IT
	Morrisville	4	07/20/2021	07/24/2021	Meter Run Replacement, No Flow to TGP	
	UP-1	1	07/20/2021	07/20/2021	16" Mag & Caliper Pig Run from UP-13 to UP-7	
	Quantico	1	07/21/2021	07/21/2021	Engine # 1 Annual Maintenance (Solar)	

	UP-1	1	07/21/2021	07/21/2021	16" MFL Pig Run from UP-13 to UP-7	
	Quantico	1	07/22/2021	07/22/2021	Engine # 2 Annual Maintenance (Solar)	
	LN-546	8	07/23/2021	07/31/2021	Outage Randall to Warsaw	
	LN-34	5	07/26/2021	07/31/2021	Outage Sabinsville Jct to Bellan	
	Rural Valley	1	07/26/2021	07/26/2021	#1 Emissions Test	
	TL-380	4	07/26/2021	07/30/2021	Outage Mcilwain to Southbend	
	LN-19	7	07/26/2021	08/02/2021	Outage Valley Gate 29 to LN-19 Regulation GA-1202 at Rural Valley	Possible Firm, Sec & IT
	TL-263	4	08/01/2021	08/05/2021	Outage Maple Fork to Chelyan 1st part	
	Herkimer M&R	4	08/01/2021	08/05/2021	Temporary Bypass and Measurement	
	LN-505	4	08/01/2021	08/05/2021	Outage Cortland High to Cortland Low	
	Cortland Low	4	08/01/2021	08/05/2021	Outage Cortland Low M&R	
	TL-263	4	08/01/2021	08/05/2021	Outage Maple Fork to Chelyan 2nd part	
	Carroll	6	08/02/2021	08/08/2021	Glycol Remediation	
	TL-400	6	08/02/2021	08/08/2021	Outage Pickerington to Groveport	Possible Firm, Sec & IT
	Oakford	10	08/02/2021	08/12/2021	#1-12 Emissions Test	
	TL-373	10	08/02/2021	08/12/2021	Outage Bridgeport to Pepper	
	Newark	6	08/02/2021	08/08/2021	Glycol Remediation	
	Washington	1	08/02/2021	08/02/2021	Station ESD	
	Washington	6	08/02/2021	08/08/2021	Glycol Remediation	
	LN-31	10	08/03/2021	08/13/2021	Outage Benjamin Hill to Ithaca High	
	Groveport	1	08/03/2021	08/03/2021	Station ESD	
	Plum Run	2	08/03/2021	08/05/2021	Bidirectional Meter, No flow from DEO	
	Lebanon	1	08/05/2021	08/05/2021	Station ESD	
	TL-400 ext. 1	7	08/09/2021	08/16/2021	Outage Allegheny River West to Allegheny River East	Possible Firm, Sec & IT
	TL-400 ext. 1	7	08/09/2021	08/16/2021	Outage Mushroom mine to Allegheny River West	Possible Firm, Sec & IT
	TL-400 ext. 1	7	08/09/2021	08/16/2021	Outage Valley Gate 29-A to Rural Valley Unit #3	Possible Firm, Sec & IT
	Newark	4	08/09/2021	08/13/2021	#3 Overhaul Exchange	
	LN-548	5	08/09/2021	08/14/2021	Outage Brandes to W. Wellsville	Possible Sec & IT
	Myersville	2	08/10/2021	08/12/2021	Borescope Inspections	
	JP-265	7	08/10/2021	08/17/2021	Outage South Oakford to Earheart, Replace mainline crossovers	Possible Sec & IT
	LN-34	6	08/10/2021	08/16/2021	Outage Chatham to Dolly Place	
	TL-590	2	08/16/2021	08/18/2021	Outage Burch to Crayne	
	LN-19	46	08/16/2021	10/01/2021	Outage JB Tonkin to Bell Point	
	Davis	1	08/16/2021	08/16/2021	#1 & 2 Emissions Test	
	Woodhull	28	08/16/2021	09/13/2021	Unit #2 Pocket Automation, Muffler, Cooler	
	LN-30	30	08/16/2021	09/15/2021	Outage South Cortland to Cheningo	Possible Sec & IT
	TL-430	2	08/23/2021	08/25/2021	Outage Lancaster to 442 Jct.	Possible Firm, Sec & IT
	LL Tonkin	6	08/23/2021	08/29/2021	#3 Rebuild	

	JB Tonkin	1	08/23/2021	08/23/2021	#1 Emissions Test	
	East Avon	4	08/23/2021	08/27/2021	Outage East Avon M&R	
	LN-12	18	08/23/2021	09/10/2021	Outage Sabinsville to Stateline	
	Chambersburg	2	08/24/2021	08/26/2021	Borescope Inspections	
	TL-430	2	08/26/2021	08/28/2021	Outage Auburn Jct. to Oka Jct.	
	LN-545	67	08/30/2021	11/05/2021	Outage Lamunion to Oneida	
	Ardell	1	08/30/2021	08/30/2021	#1-4 Emissions Test	
	TL-294	2	08/30/2021	09/01/2021	Outage 442 Jct. to Dry Fork 2	
	LL Tonkin	7	08/30/2021	09/06/2021	#2 Rebuild	
	TL-387	1	08/30/2021	08/31/2021	Outage Vista Del Rio to W. Sabraton	
	TL-377	20	09/01/2021	09/21/2021	Outage Mockingbird to Furbee Jct.	
	TL-371	2	09/01/2021	09/03/2021	Outage Oxford to Prunty Jct.	
	LN-26	2	09/01/2021	09/03/2021	Outage Kiski River to Burrell	
	TL-361	6	09/06/2021	09/12/2021	Outage Dry Fork 2 to Marts Jct.	
	Rural Valley	6	09/06/2021	09/12/2021	Glycol Remediation #3	
	Schutte	1	09/07/2021	09/07/2021	#3 Emissions Test	
	JP-40	3	09/07/2021	09/10/2021	Outage Henery Gate to Jeanette Station	
	LN-543	9	09/08/2021	09/17/2021	Outage Horseheads to Gardner	Possible Firm, Sec & IT
	LN-24	6	09/12/2021	09/18/2021	Outage Hume to Genesee Falls	
	LN-24	3	09/13/2021	09/16/2021	Outage Randall to Genesee Falls	
	Sharon	4	09/13/2021	09/17/2021	Fall Shut In Test	
	Racket	4	09/13/2021	09/17/2021	Fall Shut In Test	
	LN-280	10	09/13/2021	09/23/2021	Outage Big Run Jct. to Ardell	
	Punxsutawney	1	09/13/2021	09/13/2021	#1-3 Emissions Test	Possible Firm, Sec & IT
	Mockingbird	27	09/13/2021	10/10/2021	Solar work Engine unavailable	
	Greenlick	4	09/20/2021	09/24/2021	Fall Shut In Test	
	LN-41	9	09/20/2021	09/29/2021	Outage Chatham to Woodhull	
	Spruce Run	1	09/20/2021	09/20/2021	#1-2 Emissions Test	
	TL-370	2	09/20/2021	09/22/2021	Outage Oxford to Prunty Jct.	
	Bridgeport	4	09/20/2021	09/24/2021	Fall Shut In Test	
	Southbend	4	09/20/2021	09/24/2021	Fall Shut In Test	
	Quinlan	4	09/27/2021	10/01/2021	Fall Shut In Test	
	Washington	1	09/27/2021	09/27/2021	#1 -3 Emissions Test	
	North Summit	4	09/27/2021	10/01/2021	Fall Shut In Test	
	Silver Springs	1	10/04/2021	10/04/2021	#1 & 2 Emissions Test	
	Tioga	4	10/04/2021	10/08/2021	Fall Shut In Test	
	Woodhull	4	10/04/2021	10/08/2021	Fall Shut In Test	
	Gilmore	18	10/04/2021	10/22/2021	Valve Replacements	Possible Sec & IT
	5th Sand	4	10/04/2021	10/08/2021	Fall Shut In Test	
	Sabinsville	4	10/11/2021	10/15/2021	Fall Shut In Test	
	Sabinsville	4	10/11/2021	10/15/2021	Unit #4 Cooler	
	FKLC	4	10/11/2021	10/15/2021	Fall Shut In Test	

	Cornwell	1	10/11/2021	10/11/2021	#9 Emissions Test	
	Sabinsville	4	10/11/2021	10/15/2021	Yard Valve Replacement	
	Leidy	4	10/18/2021	10/22/2021	Fall Shut In Test	
	Finnefrock	1	10/18/2021	10/18/2021	#8 Emissions Test	
	Harrison	4	10/25/2021	10/29/2021	Fall Shut In Test	
	Murrysville	3	10/26/2021	10/28/2021	Fall Shut In Test	
	Myersville	1	11/01/2021	11/01/2021	#1 & 2 Emissions Test	
	Ellisburg	4	11/01/2021	11/05/2021	Fall Shut In Test	
	Sabinsville	4	11/15/2021	11/19/2021	Unit #9 Discharge Check Valve Replacement	
	Centre	1	11/29/2021	11/29/2021	#1 & 2 Emissions Test	
	Crayne	1	12/06/2021	12/06/2021	#1-3 Emissions Test	
	Chambersburg	1	12/13/2021	12/13/2021	#3 Emissions Test	